

ARC FLASH MITIGATION

The Latest Technique for Fire Pump Controllers
By Master Control Systems, Inc.



ARC FLASH FOR A FIRE PUMP CONTROLLER

The arc flash energy available at the input terminals of a fire pump controller can be extremely high or unlimited!



DANGER

**NO SAFE PPE EXISTS
ENERGIZED WORK PROHIBITED**

IT'S SO HIGH THAT...

“Hot” work can't be safely conducted on a typical fire pump controller.

Let's see why...


A real test lab video

To see video, go to:

www.mastercontrols.com

Click on the 100,000 AMPs video play
button on the home page


WHY IS THE ENERGY SO HIGH?



- NFPA 20, Arrangement A

- The power source to the fire pump controller is a Service directly from the utility. NFPA 20 9.2.2(1), NEC 695.3(A)(1).
- The building Service overcurrent protection on the utility side is likely to be so large that it won't trip on an arc fault in the fire pump controller.


WHY IS THE ENERGY SO HIGH?



• Arrangement A (cont'd)

- Wire brought to the controller for a 250 hp, 460 vac motor will be 500 kcmil/phase so the short circuit current can be 100 kA.
- The incident energy for this circuit can't be calculated, since the line side circuit protection can't be evaluated.
- Thus, energized work is prohibited. To work on the fire pump controller, the building power must be shutdown by the utility. This make trouble shooting very difficult.


OTHER ARRANGEMENTS



- NFPA 20, Arrangement B

- If the Service voltage is greater than the utilization voltage, a dedicated transformer is required per NFPA20 9.2.2(5) and a service disconnect per NFPA20 9.2.3, NEC 695.4(B)(1).
- The overcurrent protection for the transformer is to be sized for locked rotor current per NEC 695.5(B).
- For a 250 hp, 460 vac motor, the locked rotor protection will be sized for 2000 amps.
- The incident energy at the controller can now be calculated, but will be quite high.

OTHER ARRANGEMENTS



- NFPA 20, Arrangement C

- A single service disconnect is allowed per NFPA20 9.2.3 or NEC 695.4(B)(1).
- The overcurrent protection is typically sized to 9.2.3.4 or NEC 695.4(B)(2)(a)(1) for locked rotor current.
- For a 250 hp, 460 vac motor, the locked rotor protection will be sized for 2000 amps.
- The incident energy at the controller can now be calculated, but will be quite high.


INSTALLED SIS FIRE PUMP CONTROLLER



- SIS compartment is located on the far left side by default.
- SIS can be on the right side if specified accordingly.
- Incoming power allowed from the top, but must be installed with waterproof hubs.

MASTER Model ECVST-350-46-XG4,SIS

MITIGATION TECHNIQUE



- Use Arrangement A with SIS
 - The power source to the fire pump controller is a Service directly from the utility. NFPA 20 9.2.2(1), NEC 695.3(A)(1).
 - Add Modification SIS to the fire pump controller.
 - The arc flash incident energy with the SIS has been verified by an independent NRTL laboratory to be less than 0.5 cal/cm².

MITIGATION TECHNIQUE



- MASTER Modification SIS
 - Moves Isolating switch into a separate enclosure.
 - Locally disconnects power to main fire pump controller.
 - Allows “hot” work with basic PPE.
 - Reduces the Arc-Flash incident energy in the fire pump controller main cabinet to less than 0.5 cal/cm².
 - Verified by an independent NRTL laboratory.
 - Substantially reduces typical arc flash mitigation costs.