


**MASTER CONTROL SYSTEMS**

PUMP RUNNING	AC POWER	PHASES REVERSED
FAILURE TO START	SUPERV POWER	MOTOR OVERLOAD
MOTOR TRIP	AC VOLTS LOW	FUSE BLOWN
RELIEF VALVE OPEN	FLOW METER OPEN	RESERVOIR LEVEL LOW

**DIGITAL READOUT**



**START DEMANDS**

PRESSURE  DELUGE VALVE

REMOTE START  LOCAL START

**TIMING**

RESTART  BREAKER

SEQUENCE  ACCELERATE

**STATUS**

COMMIT TO RUN  LOCKOUT

FULL VOLTAGE  MINIMUM RUN