

EQUIPMENT ORDERED

COMPLETE CONTROLLER MODEL NO. _____
 IN TYPE 12 DUSTTIGHT, DRIPTIGHT ENCLOSURE (OR AS INDICATED BELOW)
 FOR USE WITH _____ V.D.C. _____ GROUND SYSTEM FOR TWO BATTERY UNITS
 EACH HAVING (QTY) _____ TYPE _____ CELLS WITH MAX. CAPACITY SHOWN BELOW
 INPUT POWER _____ V.A.C. AT _____ HZ. SINGLE PHASE _____ AMP MAX.
 (BRANCH CIRCUIT REQUIRED, 15 AMP BRANCH IS ADEQUATE).
 ENGINE MAKE _____ ENGINE MODEL _____

- G3 (RA) - BUILT IN DUAL BATTERY CHARGER WITH DUAL CHARGER MALFUNCTION ALARMS - 230 AH
- DA - BUILT IN DUAL BATTERY CHARGER WITH DUAL CHARGER MALFUNCTION ALARMS - 450 AH (UL & NFPA)

INCLUDES OPTIONS CHECKED BELOW:

- G3 (H)- SHUTDOWN SOLENOID CIRCUIT (LISTED CATERPILLAR ENGINES)
- M- MANUAL, NON-AUTOMATIC (REMOVES PRESSURE SWITCH & ADDS WEEKLY TEST RELAY)
- G3 (D)- PUMP HOUSE ALARM & SIGNALS (PER N.F.P.A. 20)
 WHICH INCLUDES:

SIGNAL LAMPS

- | | |
|---|--|
| <input checked="" type="checkbox"/> LOW FUEL LEVEL | <input checked="" type="checkbox"/> FUEL SPILL |
| <input checked="" type="checkbox"/> SYSTEM OVERPRESSURE | <input checked="" type="checkbox"/> PUMP ROOM TEMP LOW |
| <input checked="" type="checkbox"/> RESERVOIR LOW | <input checked="" type="checkbox"/> LEAK DETECTION |
| <input checked="" type="checkbox"/> RESERVOIR EMPTY | <input type="checkbox"/> _____ |
| <input type="checkbox"/> _____ | <input type="checkbox"/> _____ |

- G3 (1)- AUTOMATIC STOP (INCLUDES MINIMUM RUN TIMER)
- G3 (5)- POWER FAIL START (ADJUSTABLE UP TO 5 MINS)
- 7 - CONTACTS FOR INDIVIDUAL REMOTE FAILURE SIGNALS (MAXIMUM TOTAL OF 14 SIGNALS)

WHICH INCLUDES:

STANDARD EIGHT SIGNALS

- BATTERY 1 FAILURE
- BATTERY 2 FAILURE
- LOW OIL PRESSURE
- AUTO ON
- HIGH WATER TEMP
- FAILURE TO START
- OVERSPEED
- CHARGER FAILURE

PUMP HOUSE TROUBLE SIGNALS

- LOW FUEL LEVEL
- SYSTEM OVERPRESSURE
- RESERVOIR LOW
- RESERVOIR EMPTY
- FUEL SPILL
- PUMP ROOM TEMP LOW
- LEAK DETECTION
- _____
- G3 (9)- SEQUENCE STARTING

- 8 - ENERGIZED TO STOP
- X - SPECIAL MODIFICATION (SEE CODES BELOW)

INCLUDES MODIFICATIONS CHECKED BELOW:

(CONTROLLER MODEL NUMBER INDICATES MODIFICATIONS SUPPLIED)

- G3 (PN) - BUILT-IN PAPERLESS PRESSURE AND ALARM RECORDER W/INTERNET TCP/IP ACCESS
- 15A-300 PSI 300 SERIES S.S. PRESSURE SWITCH, DRAIN VALVE & WET PARTS
- G3 (12) - TYPE 12 DUST TIGHT
- 3R - TYPE 3R RAIN TIGHT
- 4 - TYPE 4 HOSE TIGHT
- 4XA - TYPE 4X ORGANIC COATING
- 4XB - TYPE 4X 304 STAINLESS STEEL
- 4XC - TYPE 4X 316 STAINLESS STEEL
- L-18 INCH LEGS
- 16-600 PSI PRESSURE SWITCH, DRAIN VALVE & WET PARTS
- 20A - HUMIDISTAT WITH FACTORY INSTALLED INTERNAL STRIP HEATER
- G3 (21T)- SHUTDOWN ON OIL AND WATER DURING WEEKLY TEST
- 32 - LOW PUMP ROOM TEMPERATURE SWITCH (REQUIRES OPT.O)
- G3 (38D)- STATUS LEDs ON LAMP PANEL
- _____
- _____

ORDER ALSO INCLUDES:

- 4817 - LOW FUEL SWITCH (SHIPPED LOOSE FOR FIELD INSTALLATION)
- 4817L - LONG ROD LOW FUEL SWITCH (FOR LARGER DIAMETER OR TALL TANKS)
- 6288 - HIGH FUEL SWITCH (SHIPPED LOOSE FOR FIELD INSTALLATION)
- REMOTE ALARM PANEL MODEL _____
- FOR REMOTE INSTALLATION AT A POINT OF CONSTANT ATTENDANCE
- _____
- _____
- _____
- _____