



This chassis is provided when the following is supplied:  
 OPT. "O": MOD. 17A, 17B, 17C, 17E. OPT. "N"-or-  
 OPT. "G": SUPERVISORY POWER LOSS START (RELAY 21)

RELAY	DESIG.	DESCRIPTION	OPT. /MOD
RY21	SPS	S.P.L. START	"G"
RY22	PHT	PUMP ROOM TRBL	"O"
RY23	LVR	AC VOLTS LOW	"N"
RY24	AMRR	PUMP RUN #2	17A
RY25	APAR	PWR. FAIL #2	17C
RY26	ASRR	PHASE SEQ.#2	17E

- NOTES:
- 1) All relay contacts shown DE-ENERGIZED.
  - 2) All contacts shown in NORMAL STATE except RY25A/C & B/D (Term. 40-42) which are shown in ALARM state.
  - 3) Alarm (S.P.D.T.) contact rating: 5.0 Amps at 115 Vac OR 28 Vdc.
  - 4) FC2 Not Used when Option "N" is supplied.
  - 5) FC3 Not Used when Mod 85C is supplied.