



NOTES:

- 1) The TEST jumper sets the shutdown time to 4.3 Seconds (Normally 30 sec.) and the Auto Reset time to 43 Seconds (Normally 300 sec.). The RESET jumper disables the Auto Reset (when supplied). The LOCK-OUT jumper enables the shutdown circuitry.
- 2) Alarm contacts rated 1.0A @ 28Vdc.

