



NOTES

- ALL RELAY CONTACTS ARE SHOWN IN THE DE-ENERGIZED (RELEASED) POSITION.
- WHEN "PRESSURE SWITCH SHUTDOWN" (OPTION 1) IS FURNISHED, THE PRESSURE SWITCH IS PROVIDED.
- WHEN "DUAL INPUT POWER" (OPTION 2) IS FURNISHED, F2, RELAY K2 & SIGNAL LAMPS SL2 & SL4 ARE PROVIDED. LAMP SL1 IS REMOVED.
- WHEN "REPETITIVE ALARM SIGNALS" (OPTION 3) IS FURNISHED, JUMPERS ON TERMINALS 31-32 & 32-33 ARE REMOVED AND RELAYS K5 & K7 ARE PROVIDED.
- WHEN "AUTOMATIC RESET DELAY" (OPTION 4) IS FURNISHED, JUMPER ON TERMINALS 34-35 IS REMOVED AND TIMER TD2 IS PROVIDED.

THIS DRAWING APPLIES TO LSSC CONTROLS WITH ANY OR ALL OF THE FOLLOWING OPTIONS:

- PRESSURE SWITCH SHUTDOWN
- DUAL INPUT POWER
- REPETITIVE ALARM SIGNALS
- AUTOMATIC RESET DELAY



SCHEMATIC DIAGRAM LSSC SHUTDOWN CONTROL FOR ELECTRIC CONTROLLERS			
MASTER CONTROL SYSTEMS INC. LAKE BLUFF, ILLINOIS U.S.A.			
USED ON	RE-PLOT	11 Sept 00	
DRN.	KWM	DES.	
APP.		DATE	30 DEC. 97
DWG.	7764	ISS. 1	SHEET 1 OF 1