

EQUIPMENT ORDERED

COMPLETE CONTROLLER MODEL NO. \_\_\_\_\_  
 IN TYPE 2 DRIP PROOF ENCLOSURE (OR AS INDICATED BELOW)  
 WITHSTAND RATED AT \_\_\_\_\_ RMS SYM. AMPS AT \_\_\_\_\_ VAC  
 FOR USE WITH \_\_\_\_\_ HP, \_\_\_\_\_ VAC, \_\_\_\_\_ PH. \_\_\_\_\_ HZ MOTOR

STARTING TYPE

- |  |  |
|--|--|
| <input type="checkbox"/> MCA-ACROSS THE LINE | <input type="checkbox"/> MCO-WYE DELTA OPEN TRANSITION   |
| <input type="checkbox"/> MCP-PART WINDING    | <input type="checkbox"/> MCO-WYE DELTA CLOSED TRANSITION |
| <input type="checkbox"/> MCR-PRIMARY REACTOR | <input type="checkbox"/> MCS-SOLID STATE (SCR)           |
|  | <input type="checkbox"/> MCT-AUTOTRANSFORMER             |

INCLUDES OPTIONS CHECKED BELOW:

(CONTROLLER MODEL NUMBER INDICATES OPTIONS SUPPLIED)

- |   |   |
|---|---|
| <input checked="" type="checkbox"/> A-AUTOMATIC STOP (G3)               | <input checked="" type="checkbox"/> P-DIGITAL PRESSURE READOUT (G3) |
| <input type="checkbox"/> C-200,000 AMP WITHSTAND RATING                 | <input type="checkbox"/> Q-INDIVIDUAL REMOTE CONTACTS FOR OPTION O  |
| <input checked="" type="checkbox"/> D-SEQUENCE START (G3)               | <input checked="" type="checkbox"/> R-REMOTE START (G3)             |
| <input checked="" type="checkbox"/> F-PUMP RUNNING LIGHT (G3)           | <input checked="" type="checkbox"/> T-WEEKLY TEST (G3)              |
| <input type="checkbox"/> G-SUPERVISORY POWER LOSS                       | <input type="checkbox"/> W-SPECIAL MOD. NOT COVERED BY CODES        |
| <input checked="" type="checkbox"/> H-100,000 AMP WITHSTAND RATING (G3) | <input type="checkbox"/> X-SPECIAL MODIFICATION (SEE CODES BELOW)   |
| <input checked="" type="checkbox"/> I-INSTRUMENTATION (G3)              | <input type="checkbox"/> Y-MOTOR OVERLOAD ALARM                     |
| <input checked="" type="checkbox"/> J-FAILURE TO START (G3)             | <input type="checkbox"/> Z-HIGH ZONE DELAYED START                  |
| <input type="checkbox"/> K-BUILT-IN ALARM SYSTEM                        | <input type="checkbox"/>  |
| <input type="checkbox"/> M-MANUAL NON-AUTOMATIC                         | <input type="checkbox"/>  |
| <input checked="" type="checkbox"/> O-PUMP ROOM ALARM AND SIGNALS (G3)  | <input type="checkbox"/>  |

INCLUDES MODIFICATIONS CHECKED BELOW:

(CONTROLLER MODEL NUMBER INDICATES MODIFICATIONS SUPPLIED)

- |   |   |
|---|---|
| <input checked="" type="checkbox"/> DR-DIGITAL RECORDER WITH USB (G3) | <input type="checkbox"/> 17D-2"C" AUX. POWER ON CONTACTS          |
| <input checked="" type="checkbox"/> SP-SINGLE PHASE PROTECTION (G3)   | <input type="checkbox"/> 17E-1"C" AUX. PHASE RVSL. CONTACTS       |
| <input type="checkbox"/> 12-TYPE 12 DRIPPROOF & DUSTTIGHT             | <input type="checkbox"/> 17F-2"C" AUX. PHASE RVSL. CONTACTS       |
| <input type="checkbox"/> 3-TYPE 3 SPLASH TIGHT                        | <input type="checkbox"/> 18-N.Y.B.S.A. APPROVALS                  |
| <input type="checkbox"/> 3R-TYPE 3R RAIN TIGHT                        | <input type="checkbox"/> 19-SPACE HEATER                          |
| <input type="checkbox"/> 4-TYPE 4 HOSE TIGHT                          | <input type="checkbox"/> 20-HEATER & THERMOSTAT                   |
| <input type="checkbox"/> 4XA-TYPE 4X ORGANIC COATING                  | <input type="checkbox"/> 20A-HEATER & HUMIDISTAT                  |
| <input type="checkbox"/> 4XB-TYPE 4X 304 STAINLESS STEEL              | <input type="checkbox"/> 21-LOCKOUT CIRCUIT                       |
| <input type="checkbox"/> 4XC-TYPE 4X 316 STAINLESS STEEL              | <input type="checkbox"/> 30-SINGLE PHASE LIMITED SERVICE          |
| <input type="checkbox"/> 8A-CONFORMAL COATING                         | <input type="checkbox"/> 32-PUMP ROOM THERMOSTAT                  |
| <input type="checkbox"/> 8E-CE DECLARATION                            | <input type="checkbox"/> 33Y-AUX. 1 AMP @ 115 VAC POWER SUPPLY    |
| <input type="checkbox"/> 15-300 PSI 316 S/S PRESSURE SW.              | <input type="checkbox"/> 34-POWER LOSS START                      |
| <input type="checkbox"/> 16-600 PSI 403 S/S PRESSURE SW.              | <input type="checkbox"/> 42A-SOFT START SPDT FAILURE CONTACTS     |
| <input type="checkbox"/> 17A-1"C" AUX. MOTOR RUN CONTACTS             | <input type="checkbox"/> 42B-TWO SOFT START SPDT FAILURE CONTACTS |
| <input type="checkbox"/> 17B-2"C" AUX. MOTOR RUN CONTACTS             | <input type="checkbox"/> 43-SOFT START FAILURE LIGHT              |
| <input type="checkbox"/> 17C-1"C" AUX. POWER ON CONTACTS              | <input type="checkbox"/> 50- 50,000 AMP WITHSTAND RATING          |
|   | <input type="checkbox"/> 150-150,000 AMP WITHSTAND RATING         |

ORDER ALSO INCLUDES:

- REMOTE ALM. PNL. \_\_\_\_\_ FOR REMOTE INSTALLATION AT A POINT OF CONSTANT ATTENDANCE
- 
- 
- 
- 

JOB IDENTIFICATION: \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_

