

Certificate of Compliance

YE00.12.MC1280.001
File Number: MC1280

MASTER CONTROL SYSTEMS INC.
910 North Shore Drive
Lake Bluff, IL 60044 USA

is authorized to affix the International "emc-Mark" for Europe to the products described as follows:

Product:	DCF**, DCM** ** - may or may not be followed by suffixes denoting: Battery Charger (R); Battery Charger Alarm (A); Timer Option (1,5); Signaling Relay (7); Pump Alarm Circuits (0); Non-critical Mods (X); Alarm Recorder (P1, P2); Status LED's (31); DC input/output Voltage; Ground Designation (N); AC input (Voltage/Freq)
Type:	Industrial Scientific Lab Equipment
Product Description:	Diesel Driven Fire Pump Controllers
Standards(s):	EN 50081-1:1992, EN 55011:1998, EN 61000-3-2:1995, EN 61000-3-3:1995, EN 50082-2:1995, EN 61000-6-2:1999, EN 61000-4-2:1995, EN 61000-4-3:1996, EN 61000-4-4:1995, EN 61000-4-5:1995, EN 61000-4-6:1996, EN 61000-4-8:1993, EN 61000-4-11:1994

The above described product(s) meet(s) the EMC standard(s) or requirements listed above or have been evaluated using a Technical Construction File (TCF) in conjunction with the standard whose requirements are not fully fulfilled. The award of this certificate is based upon the successful testing of a representative sample, the review of it's technical documentation and an initial factory audit. An annual retest of the product, annual factory surveillance audit or Management System Registration to meet requirements of ISO 9000 series is required for certificate renewal.

This Certificate is valid until cancelled by the certificate holder or the Certification Body.

03-Dec-02

UNDERWRITERS LABORATORIES INC.



This Certificate of Compliance is issued in accordance with the Procedures among Underwriters Laboratories Inc., TÜV PS, VDE, IMQ, BABT and QAS concerning the issuance of the International "emc-Mark" and the mutual recognition of test and inspections among these international certification organizations.

